

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 107950

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 63536

1. OWNER **JEFF GRIFFIN**
 MAILING ADDRESS 900 COURT ST
MARTINEZ, CA 94553
 ADDRESS AT WELL LOCATION 3079 **2079 FISH SPRINGS RD**
GARDNERVILLE, NV 89410

2. LOCATION NW 1/4 SE 1/4 Sec 6 T 12 N R 21 E **DOUGLAS** County
 PERMIT NO. SE NW **1221-06-001-039**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
BROWN CLAY		3	9	6
COURSE GRAVELS		6	82	73
BROWN CLAY		82	162	80
SMALL SILTY SANDS		162	186	24
CLAY SEAMS & SMALL GRAVELS	XXX	186	260	74
NJ 36 933062 W 49 668543 (NAD 83)				

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches 0 Feet 160 Feet
9 7/8 Inches 160 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.26	.206	20	260

Perforations:
 Type perforation **SAW CUT**
 Size perforation **3 X 3/32**
 From 220 feet to 260 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

7. WELL TEST DATE
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. 25 Draw Down (Feet Below Static) 40 Time (Hours) 3 HRS
2009 JAN 26 PM 2:03

9. WATER LEVEL
 Static water level 86 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board **0055548**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**
 Signed Michael H. Beck
 By driller performing actual drilling on site or contractor
 Date 1/15/09