

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY** 107953  
Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 108

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 57516

1. OWNER: Randy Menesini  
MAILING ADDRESS: 113 Hwy 95A North  
NE Yerington, Nv 89447

ADDRESS AT WELL LOCATION: Same  
Subdivision Name: \_\_\_\_\_ County: Lyon

2. LOCATION: NE 1/4 Sec 28 T 14N N/S R 25 E  
PERMIT/WAIVER No.: 14-291-02  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude: N 39.05177 UTM E  NAD 27  
Longitude: W 119.18265 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Top soil, hard pan		0	3	3
Coarse sand & clay stratas		3	10	7
Coarse sand & gravel		10	12	2
Coarse sand & large gravel	X	12	54	42
Coarse sand & brown clay		54	56	2
Brown clay hard		56	63	7
Brown clay soft		63	68	5
Coarse sand & large gravel	X	68	77	9
Brown clay		77	81	4
Coarse sand & large gravel	X	81	105	24
Brown clay		105	110	5
Coarse sand & gravel	X	110	121	11
Brown clay		121	124	3
Coarse sand & gravel	X	124	128	4
Coarse sand, small gravel & brown clay	X	128	146	18
Coarse sand & gravel	X	146	155	9
Brown clay		155	162	7
Coarse sand & small gravel	XX	162	179	17
Adapter PVC/Steel 12" X .280				

9. WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
<u>179</u>		<u>181</u>	<u>179</u>	
HOLE DIAMETER (BIT SIZE)				
	From	To		
<u>11 1/2</u>	Inches	<u>0</u>	Feet	<u>41</u> Feet
<u>10 5/8</u>	Inches	<u>41</u>	Feet	<u>180</u> Feet
	Inches		Feet	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>19</u>
<u>6 5/8</u>	<u>4.06</u>	<u>.316</u>	<u>19</u>	<u>179</u>

Perforations:  
Type of perforation: CertainTeed Certa-Lok slotted  
Size of perforation: 0.032 X 6 rows .25" slot spacing  
From 159 feet to 179 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 15  Pumped  Poured  
 ≥30% Bentonite Grout 15 to 50  Pumped  Poured  
Gravel Pack:  Yes  No 50 to 179  Pumped  Poured  
Type: 1/4 - 3/8" round well rock  
Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

7. Water Level  
Static water level: 18 feet below land surface  
Artesian Flow: NO G.P.M. N/A P.S.I.  
Water Temperature: Cold °F  
Quality: Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name: Ogden Drilling Contractor  
Address: 152 N. Bybee Ln Contractor  
Yerington, Nv 89447  
Nevada contractor's license number issued by the State Contractor's Board: 57011  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 634  
Signed: [Signature]  
By driller performing actual drilling on site or contractor  
Date: 1/25/2009

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Airlift</u>	<u>50+</u>	<u>90' Airline</u>	<u>3</u>