STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107991
Permit No.
Basin 072

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62820

1. OWNER TRAVEL CENTERS OF AMERICA
MAILING ADDRESS 24601 CENTER RIDGE ROAD
WESTLAKE, OHIO 44145

ADDRESS AT WELL LOCATION KULWINDER JOHAL (WELL# SVE-4)
1305 RYE PATCH RESERVIOR RD., LOCKLOCK, NV. 89419
Subdivision Name: County: Pershing

2. LOCATION SW ¼ NW ¼ Sec 16 T 30N N/S R 33 E
PERMIT/WAIVER No. 5-000012 (issued by Water Resources) 010-120-01 Parcel No.

Latitude 40° 28' 00.9"
Longitude -118° 17' 01.7"
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT	NO	0	.4	0
SANDY SILT / SMALL GRAVELS	NO	.4	15.5	15
SILTY SAND / SMALL GRAVEL	NO	15.5	23	8

N40.467026
W118.282829 NAD27

Date started: 18-Dec, 20 08
Date completed: 18-Dec, 20 08

9. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	23	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH. 40	0	16'

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .020
From 16 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 2 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 14 to 23 ☐ Pumped ☒ Poured
Type: 10/20 SILICA SAND
Bentonite Chips: ☒ Yes ☐ No 2 to 14 ☐ Pumped ☒ Poured
Type: 3/8 CHIPS

7. Water Level
Static water level: NONE feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ TECH DRILLING, INC. (Contractor)
Address PO BOX 940 (Contractor)
MERIDIAN, ID. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2137
Signed (By driller performing actual drilling on site or contractor)
Date 2-16-09 2/18/2009

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY