STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107992
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34224

1. OWNER SAVEWAY SUPER SERVICE STATIONS
MAILING ADDRESS 2424 S. HIGHLAND
LAS VEGAS NV 89102

ADDRESS AT WELL LOCATION 3225 N. LAS VEGAS BLVD.
LAS VEGAS NV.
Subdivision Name: County: CLARK

2. LOCATION NW ¼ NW ¼ Sec 18 T 20 N/S R 62 E
PERMIT/WAIVER No. 140-18-101-003
Issued by Water Resources Parcel No.

Latitude 36° 13. 012 N
Longitude 115° 05. 745
UTM E N
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ■ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ■ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MW 26				
CONCRETE		0	.5	.5
STONE FILL		.5	3.5	3.0
SAND + SILTY SOME CLAY		3.5	15	11.5
SILTY CLAY		15	50	35.0
MOIST BROWN SILTY CLAY	YES	50	65	15.0
FACILITY I.D. NO. 8-000523				

Date started: 3-4- , 20 09
Date completed: 3-4 , 20 09

9. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	65	Feet	65	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	50

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 25 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
■ Cement Grout	1	to 21	☐ Pumped	■ Poured
■ Concrete Grout	0	to 1	☐ Pumped	■ Poured
■ ≥30% Bentonite Grout	50	to 65	☐ Pumped	■ Poured

Gravel Pack: ■ Yes ☐ No 23 to 50 ☐ Pumped ■ Poured
Type: No. 3
Bentonite Chips: ■ Yes ☐ No 21 to 23 ☐ Pumped ■ Poured
Type: 3/8" SEAL

7. Water Level
Static water level: 40' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAR 1 1 2009

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST LAS VEGAS NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3-4-2009

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 06-06)

LAS VEGAS VALLEY

(NSPO 3-08) (O) 627