


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S PLUGGING REPORT**



OFFICE USE ONLY  
 Log No. 108307

Permit No. \_\_\_\_\_  
 Basin 143

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64166

1 OWNER PAT HUGHES  
 MAILING ADDRESS 240 SUTRO RD  
DAYTON NV 89403

ADDRESS AT WELL LOCATION 240 SUTRO RD  
DAYTON NV 89403  
 Subdivision Name: \_\_\_\_\_ County: Lyon

2 LOCATION SE 1/4 NE 1/4 Sec 8 T 16N N/S R 22 E  
 PERMIT/WAIVER No. 016-352-07  
Issued by Water Resources Parcel No.

Latitude 39.27079°N UTM E  NAD 27  
 Longitude 119.52847°W N  NAD 83/WGS 84

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? yes  
 If yes, what is replacement well NOR? 64165

Is there an existing well log? yes  
 If yes, what is NDWR well log #? 82405

4 EXISTING WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

7 WELL PLUGGING PROCEDURE  
 Was well cleaned out to total depth?  yes  no

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	190

If well was not cleaned out to total depth, please explain why: \_\_\_\_\_  
 Was the well contaminated?  yes  no  
 Was the casing pulled?  yes  no  
 Was the casing over drilled?  yes  no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
FACTORY MILL SLOT	3 X 3/32	150	feet to	190
			feet to	

Additional Perforations:

Type of perforator used:	Mills Knife
From <u>50</u> feet to <u>150</u> feet	Number of perms per linear foot <u>4</u>
From _____ feet to _____ feet	Number of perms per linear foot _____
From _____ feet to _____ feet	Number of perms per linear foot _____
From _____ feet to _____ feet	Number of perms per linear foot _____
From _____ feet to _____ feet	Number of perms per linear foot _____
From _____ feet to _____ feet	Number of perms per linear foot _____

5 WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cold °F Quality poor

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	neat cement	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>0</u>	feet to <u>190</u>	feet	neat cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments  
PLACED 1 1/4 TRIMMIE TO BOTTOM AND PUMPED NEAT CEMENT FROM BOTTOM TO SURFACE  
39.270765°N  
119.527465°W  
NAD 27

Neat Cement Fluid Weight 94/4 lbs/gal  
 Bentonite Grout \_\_\_\_\_ % bentonite  
 Date Started 04/27/2009  
 Date Completed 04/27/2009

REC'D  
 2009 MAY -7 PM 12:11  
 STATE ENGINEERING DIVISION

9 DRILLER'S CERTIFICATION  
 This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC  
Contractor  
 Address # 20 KIT KAT DRIVE  
Contractor  
CARSON CITY NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Black  
By driller performing actual drilling of site or contractor  
 Date 05/02/2009

USE ADDITIONAL SHEETS IF NECESSARY