REPORT NO. A9.22

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 108312
PERMIT NO. 73582
BASIN 087

NOTICE OF INTENT NO. 63751

1. OWNER Hidden Valley Country Club
MAILING ADDRESS 3575 E. Hidden Valley Dr, Reno NV 89502
ADDRESS OF WELL 3575 E. Hidden Valley Dr
Reno, NV 89502

2. WELL LOCATION NW 1/4 NE 1/4 SEC. 27 T 19 R 20 E Washoe COUNTY
PERMIT NO 73582 PARCEL NO 51-400-30 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE PER sampl bch REC + DOM use
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Clay		385	420	35
Sand		420	440	20
Clay		440	465	25
Sand		465	480	15
Fractured Red & Black Rock	X	480	570	90
Clay		570	655	85
Fractured Red & Black Rock	X	655	670	15
Clay		670	690	20
Fractured red & Black Rock	X	690	740	50
Clay		740	750	10
Fractured Red & Black Rock	X	750	800	50
Clay		800	840	40
Fractured Red & Black Rock	X	840	900	60

2009 JUN 17 AM 10:31 STATE ENGINEER

Notes : WGS-84 GPS: Latitude: N39 29.~~210~~ 249 Longitude: W119 43.37~~X~~ 7
Refer to Original Well Log for Seal #101179
39.487,591°N
119.721,947°W — DD.NAD27

Date Started 04/02/2009 Date Completed 06/04/2009

7. WELL TEST DATA

TEST METHOD [ ] Bailer [X] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	525	112.5	4

8. WELL CONSTRUCTION
Depth Drilled 900' Depth Cased 900'

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches 385 Feet 900 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
10.75"	28.06	.250	+2'	900'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 500 Feet to 540 Feet
From 660 Feet to 800 Feet
From 840 Feet to 880 Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [ ] Yes [X] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 50 Feet Below Land Surface
Artesian Flow No GPM PSI
Water Temperature 72 F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2187
Signed Roger Mitchell
By driller performing actual drilling on site or contractor
Dated June 15-2009