STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108329
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63488

1. OWNER Washoe County
MAILING ADDRESS 4930 Energy Way
Reno, NV 89502

ADDRESS AT WELL LOCATION Edison Way 250ft N. of Ampere Dr
Reno, NV
Subdivision Name: CMT-86 County: Washoe

2. LOCATION NE ¼ SE ¼ Sec 17 T 19N N/S R 20 E
PERMIT/WAIVER No. MO1517 (Issued by Water Resources) Parcel No.

Latitude
Longitude
UTM E 263315 [x] NAD 27
N 4376780 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown gravel w/sand		0	10	10
Brown silty gravel w/sand		10	21	11
Brown sand w/gravel		21	30	9
Brown silty gravel w/sand		30	37	7
Brown fine coarse sand		37	46	9
Brown silty gravel w/sand		46	54	8
Brown fine coarse sand		54	60	6
Brown sand w/gravel		60	66	6
Brown silty gravel w/sand		66	85	19

39.509,960°N NAD27
119.752,940°W

Date started: 7-Oct, 20 08
Date completed: 9-Oct, 20 08

9. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	85	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 80 PVC	70	0

Perforations:
Type of perforation Factory cut
Size of perforation .020
From 85 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 66 to 1 [x] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 85 to 68 [ ] Pumped [x] Poured
Type: Cemex 2/12
Bentonite Chips: [x] Yes [ ] No 68 to 66 [ ] Pumped [x] Poured
Type: Pure gold 3/8

7. Water Level
Static water level: 7.86 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 54.3 °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [x] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	3		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address PO Box 141 (Contractor)
Zamora, CA 95698
Nevada contractor's license number issued by the *State Contractor's Board* 12852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* T2111
Signed (By driller performing actual drilling on site or contractor)
Date 10/9/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY