STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108336
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63495

1. OWNER Washoe County
MAILING ADDRESS 4930 Energy Way
Reno, NV 89502

ADDRESS AT WELL LOCATION Clemson Rd 450ft S of Princeton Dr.
Reno,NV
Subdivision Name: CTM-93 County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 18 T 19N N/S R 20 E
PERMIT/WAIVER No. MO1517
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 260491 [x] NAD 27
N 4376874 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy gravel w/cobbles		0	8	8
Brown coarse sand w/gravel		8	19	11
Brown silty clay		19	23	4
Tan cobbelly gravel w/sand		23	35	12
Grey clayey gravel w/sand		35	45	10
Brown gravely sand		45	51	6

39.510,024°N NAD 27
119.755,784°W

Date started: 8-Jan, 20 09
Date completed: 8-Jan, 20 09

9. WELL CONSTRUCTION
Depth Drilled 51 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	51	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 80 PVC	0	45

Perforations:
Type of perforation Factory Cut
Size of perforation .020
From 50 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 40 [x] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 51 to 43 [ ] Pumped [x] Poured
Type: Cemex 2/12
Bentonite Chips: [x] Yes [ ] No 43 to 40 [ ] Pumped [x] Poured
Type: Pure gold med chips

7. Water Level
Static water level: 14.95 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 56 °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [x] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	3		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address PO Box 141
Contractor
Zamora, CA 95698
Nevada contractor's license number issued by the *State Contractor's Board* 12852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2377
Signed William Zamora
By driller performing actual drilling on site or contractor
Date 1/8/2009

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY