


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY 108358

Log No. _____
Permit No. _____
Basin 1108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61627

1. OWNER Hawthorne Army Depot
MAILING ADDRESS 15 Maine St
Hawthorne, NV 89415

ADDRESS AT WELL LOCATION _____
Subdivision Name: _____ County: Mineral

2. LOCATION NE ¼ SE ¼ Sec 32 T 09N N/S R 30 E
PERMIT/WAIVER No. #9B
Issued by Water Resources Parcel No. _____

Latitude UTM E 38,59 692 NAD 27 NAD 83/WGS 84
Longitude N 118,654 43 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other Abandon

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
30% Solids Grout		0	23.68	24
14.2 Gallon per bag				
2.2 CF of yeild				
Cut off 5' bgs concrete cap				
<p><i>NA037 DD</i> <i>38.596, 999' N</i> <i>118.653, 461' W</i></p>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	23.68	Feet
HOLE DIAMETER (BIT SIZE)				
	From	To		
	Inches	Feet		Feet
	Inches	Feet		Feet
	Inches	Feet		Feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40 PVC	0	23.68
Perforations:				
Type of perforation _____				
Size of perforation _____				
From _____	feet to _____			feet
From _____	feet to _____			feet
From _____	feet to _____			feet
From _____	feet to _____			feet
From _____	feet to _____			feet
Annular Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
<input type="checkbox"/> Neat Cement	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> Cement Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> Concrete Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	0 to 23.68	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
Gravel Pack: <input type="checkbox"/> Yes <input type="checkbox"/> No	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
Type: _____				
Bentonite Chips: <input type="checkbox"/> Yes <input type="checkbox"/> No	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
Type: _____				

RECEIVED
 JUL 09 2009
 STATE ENGINEERS OFFICE

Date started: 16-Mar 20 09
Date completed: 3/16/2009 20 09

7. Water Level
Static water level: 20.99 feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address PO Box 141
Contractor
Zamora, CA 95698
Nevada contractor's license number _____
issued by the State Contractor's Board 12852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 3/17/2009