

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY 108367

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 110B

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61636

1. OWNER Hawthorne Army Depot  
MAILING ADDRESS 15 Maine St  
NV Hawthorne, NV 89415

ADDRESS AT WELL LOCATION \_\_\_\_\_  
Subdivision Name: \_\_\_\_\_ County: Mineral

2. LOCATION NE ¼ SE ¼ Sec 32 T 09N N/S R 30 E  
Latitude UTM E 38,597 06  NAD 27  DO  
PERMIT/WAIVER No. #17 Longitude N 118,655 75  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other Abandon

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
30% Solids Grout		0	26.37	26
14.2 Gallons of water per bag				
2.2 CF yield				
Cut off 5' bgs concrete cap				
<u>NAO 27 00</u>				
<u>38.597, 139°W</u>				
<u>118.654, 781°W</u>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
		26.37	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
Inches			
Inches			
Inches			

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40 PVC	0	26.37

Perforations:

Type of perforation \_\_\_\_\_  
Size of perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout 0 to 26.37  Pumped  Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 16-Mar , 20 09  
Date completed: 3/16/2009 , 20 09

7. Water Level  
Static water level: 21.07 feet below land surface  
Artesian Flow: NA G.P.M. P.S.I.  
Water Temperature: NA °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells  
Contractor

Address PO Box 141  
Contractor

Zamora, CA 95698

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 12852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller, 2111

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 3/17/2009

RECEIVED  
JUL 09 2009  
STATE ENGINEER'S OFFICE