STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108820
Permit No.
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64112

1. OWNER Krawlzyk Edward
MAILING ADDRESS 8175 S. Virginia St. #850
Reno, NV 89571

ADDRESS AT WELL LOCATION 1805 Monte Vista Dr.
Reno,NV 89511
Subdivision Name: County: Washoe

2. LOCATION NW ¼ NE ¼ Sec 18 T 18N N/S R 20 E
PERMIT/WAIVER No. DOM 09-017 (Issued by Water Resources) 044-362-08 Parcel No.
Latitude 39. 43277 Longitude 119. 77736
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other x mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	4	
bolder & sand		4	37	
sand & clay		37	123	
clay		123	140	
sand & gravel	x	140	197	
clay		197	212	15
sand & gravel	x	212	235	23
clay		235	240	5

39.432859°N
119.776334°W
NAD27

Date started: 4-Sep, 20 09
Date completed: 10-Sep, 20 09

7. Water Level
Static water level: 80 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	20	
20	45	
30	80	
60	100	

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	240 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	188	+2	240

Perforations:
Type of perforation factory mill slot
Size of perforation 3/32"
From 180 feet to 200 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 240 ☐ Pumped ☒ Poured
Type: 1/4" pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 4850 Joule St. Suite A5 (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2121
Signed Steve McKay (By driller performing actual drilling on site or contractor)
Date 9/11/2009

RECEIVED 2009 SEP 28 AM 11:58 STATE ENGINEER'S OFFICE

(Rev. 05-05)

USE ADDITIONAL SHEETS IF NECESSARY