

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY 108851

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 137B

NOTICE OF INTENT NO. 32814

1. OWNER WARREN COVERSTONE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 94 GILLMAN SPRINGS CIRCLE 94 GILLMAN SPRINGS CIRCLE
AUSTIN NEV 89310 AUSTIN NEV 89310
 2. LOCATION SE 1/4 NW 1/4 Sec. 10 T. 16 N. 44 E. LANDER County _____
 PERMIT NO. 04-031-14 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name GILLMAN SPRINGS RANCHO

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	4	4
GRAVEL		4	7	3
BROWN CLAY		7	9	2
GRAVEL		9	16	7
BROWN CLAY		16	36	20
GRAVEL		36	42	6
TAN CLAY		42	51	9
GRAVEL		51	54	3
TAN CLAY		53	71	18
GRAVEL		71	75	4
YELLOW CLAY		75	80	5
GRAVEL		80	83	3
YELLOW CLAY		83	86	3
GRAVEL	X	86	91	5
WHITE CLAY		91	94	3
TAN CLAY		94	98	4
GRAVEL	X	98	108	10
DARK BROWN CLAY		108	113	5
BROWN CLAY & GRAVEL		113	119	6
GRAVEL	X	119	126	7
GREEN CLAY		126	133	7
GRAVEL	Y	133	142	9
TAN CLAY		142	163	21
SMALL GRAVEL		163	165	2

N39.266277°
W117.020191°
NAD 27

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 50 Feet
8 7/8 Inches _____ Feet 165 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>7.2</u>	<u>165</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/8
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow NO G.P.M. 20 P.S.I.
 Water temperature 56 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC. Contractor
 Address 2220 STONE DR. Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board: 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1442
 Signed Thomas M. Haines
 By driller performing actual drilling on site or contractor
 Date 5-9-97

Date started 5-7 1997
 Date completed 5-9 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>7 HRS</u>