

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 108877

Permit No. _____
 Basin 073

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63795

1. OWNER Ron Ward ADDRESS AT WELL LOCATION Lovelock NV
 MAILING ADDRESS 6230 Ingleston Dr#225 Sparks, Nv Subdivision Name: _____ County: Pershing
 2. LOCATION SE 1/4 NW 1/4 Sec 23 T25 N R31 E Latitude N40°02295 UTM E _____ NAD 27
 PERMIT/WAIVER NO. _____ Parcel No. 07-451-42 Longitude W118°47401 N _____ NAD 83/WGS 84
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Rock		0	50	50
clay		50	60	10
3/4 gravel		60	70	10
brown clay & rock		70	120	50
white clay		120	130	10
blue clay		130	150	20
white clay/rock		150	210	60
Brown Clay		210	230	20
reddish clay/rock		230	290	60
rock		290	310	20
course sand	X	310	320	10

40.023039°N
 118.473031°W
 NAD 83
 (70)

9. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches _____ 0 Feet _____ 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	320

Perforations:
 Type of perforation Factory Cut Slots
 Size of perforation 3/32X4
 From 280 feet to 320 feet
 From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 50 to 320 Pumped Poured
 Type: _____
 Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

Date started: May 20, 20 09
 Date completed: June 1, 20 09

7. Water Level
 Static water level: 157 feet below land surface
 Artesian Flow: N/A G.P.M. N/A P.S.I.
 Water Temperature: Cool °F
 Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>2-4</u>	<u>15:11</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling, Inc.
 (CONTRACTOR)
 Address 10760 S. Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed Fred Anderson Drilling Inc
 By driller performing actual drilling on site or contractor
 Date July 3, 2009