

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 108892  
Permit No. 869  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63413

1. OWNER Leo & Stella Hunter ADDRESS AT WELL LOCATION 4100 Hwy 95 North  
MAILING ADDRESS 3245 Fountain Way Winnemucca, Nv 89445  
Winnemucca, Nv 89445 Subdivision Name: 0 County: Humboldt

2. LOCATION SE1/4 SE1/4 1/4 Sec 22 T 38N N/S R 38E E Latitude 41 09.074n UTM E NAD 27  
PERMIT/WAIVER No. 0 Parcel No. 006-342-15 Longitude 117 41.082w N

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE Cable  Rotary  RVC  
Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
topsoil		0	2	
granite sand, gravel		2	90	
granite sand, gravel, gray clay str.		90	125	
gravel, sand		125	280	
hard gray shale		280	290	

9. WELL CONSTRUCTION  
Depth Drilled 290 Feet Depth Cased 280  
HOLE DIAMETER (BIT SIZE)  
From 0 Feet To 280 Feet  
10 7/8 Inches  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FT (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	280

Perforations:  
Type of perforation 6 inch pvc mill horizontal slot screen  
Size of perforation 1/32  
From 220 feet to 280 feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  
Neat Cement to Pumped Poured  
Cement Grout 4 to 100 Pumped  Poured  
Concrete Grout to Pumped Poured  
≥30% Bentonite Grout to Pumped Poured  
Gravel Pack:  Yes No 105 to 290 Pumped  Poured  
Type: 3/8 minus  
Bentonite Chips:  Yes No 100 to 105 Pumped  Poured  
Type: 3/8 baroid

check your well bid depth against log depth 0.00  
Date started: 6/10/2009  
Date completed: 6/15/2009

7. Water Level  
Static water level: 218 feet below land surface  
Artesian Flow: G.P.M. P.S.I.  
Water Temperature: COLD °F  
Quality:

8. WELL TEST DATA

TEST METHOD:	Ballor		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	x		
AIR	est 20		4			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name High Desert Drilling LLC  
Contractor  
Address 4225 E Mary Way  
Contractor  
Winnemucca Nevada 89445  
Nevada contractor's license number 62237  
Issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140  
Signed Isaac Johnson by Isaac Johnson  
By driller performing actual drilling on site or contractor  
Date

USE ADDITIONAL SHEETS IF NECESSARY

2009 JUL 16 11:06 AM