

NOTICE OF INTENT NO. 60454

1. OWNER Chevron Env. Management Co. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6001 Bollinger Cny Rd 947 Tahoe Blvd.
San Ramon, CA 94583 Incline Village, NV 89451
 2. LOCATION NW 1/4 NE 1/4 Sec 15 T16 (N) R 18 E Washoe County
 PERMIT NO. _____ Parcel No. 132-231-10 Subdivision Name Incline

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Air Spurge
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brn silty sand		0	6	6
brn sand, Gravel, small cobbles		6	16	10
greyish br sand fine to coarse, some gravel		16	22	6
brn silty cl w/ sand, gravel		22	32	10
greyish br silty sand, moist fine to med		32	37	5
brn grey sand w/ silt, clay, gravel		37	41	4
brn grey silty clay & sand		41	47	6

AS-3

N: 14767637.69
 E: 2238970.93
 39.258572°N
 119.944502°W

NAD 83
 NAD 22

8. WELL CONSTRUCTION
 Depth Drilled 47 Feet Depth Cased 37 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 47 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/4</u>	<u>Schd 80</u>	<u>90</u>	<u>0</u>	<u>37</u>

Perforations:
 Type perforation Slotted
 Size perforation .020
 From 36 feet to 37 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1'-39"/33'-35
 Neat Cement
 Placement Method: Pumped med chips
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 35 feet to 37 feet

9. WATER LEVEL
 Static water level 32' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature c °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mario Romero / Prosonic Contractor
 Address 12464 McCann Dr Contractor
Santa Fe Springs CA 90670
 Nevada contractor's license number issued by the State Contractor's Board 5971500
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2313
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 8-23-07

Date started 7-20, 2007
 Date completed 7-20, 2007


7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

Time (Hours)	Draw Down (Feet Below Static)	Flow Rate (GPM)
_____	_____	_____

RECEIVED
 2008 OCT 10 AM 10:15
 STATE ENGINEERS OFFICE

Map of Site:



RECEIVED
 2007 OCT -1 AM 10:12
 STATE ENGINEERS OFFICE
 RECEIVED
 2008 JUL 10 AM 10:15
 STATE ENGINEERS OFFICE


SECOR

JOB NAME _____
 JOB NO. _____
 CALCULATED BY _____ DATE _____
 CHECKED BY _____ DATE _____
 SHEET _____ OF _____

Scale:
 1" = 20'

VSE 20 scale
 on 20' bearing

City of Black
 11/10/10



RECEIVED
 2008 JUL 10 AM 10:15
 STATE ENGINEERS OFFICE

RECEIVED
 2007 OCT -1 AM 10:12
 STATE ENGINEERS OFFICE

