WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 109734
Log No.
Permit No.
Basin 110C

NOTICE OF INTENT NO. 60959

1. OWNER Hawthorne Army Depot (Kevin Shannon)
MAILING ADDRESS 25 Maine Bldg #5
Hawthorne, NV 89415

ADDRESS AT WELL LOCATION Hwy-95
Hawthorne Army Depot

2. LOCATION NW ¼ NW SE ¼ Sec. 14 10 T. 8 N/S R. 30 E. Mineral County

PERMIT NO. M/D-1475/9-000031 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy gravel		0	60	60
silty sand		60	67	7
gravel		67	72	5
sand (course		72	94	22
sand (fine)		94	112	18
38.565295°N				
118.619551°W				
NAD 27 (TA)				
Bentonite chips		97'-100'		
GPS coords:				
N 38° 33' 54.76"				
W 118° 37' 13.84"				
datum: WGS 84				

Date started 11/28/, 2007
Date completed 11/29, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 112 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	112 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	sch 40		0	102

Perforations:
Type perforation factory slotted
Size perforation .020
From 102 feet to 112 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-97
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 112 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bonnet Longyear (Contractor)
Address 12464 McCann Drive (Contractor)
Santa Fe Springs, CA 90670
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-~~1798~~ 2198
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/27/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY J03-SB6 (O)-627