WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 109767
Log No.
Permit No.
Basin 110C

NOTICE OF INTENT NO. ~~60960~~ 60959

1. OWNER Hawthorne Army Depot (Kevin Shannon)
MAILING ADDRESS 25 Maine Bldg 5
Hawthorne, NV. 89415

ADDRESS AT WELL LOCATION Hwy 95
Hawthorne Army Depot

2. LOCATION ~~NW~~ SE ¼ NW ¼ Sec. ~~14~~ 10 T. 8 N/S R. 30 E. Mineral County
PERMIT NO. M/0-1475/9-000031
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other Temp

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand w/ gravel		0	11	11
Silty Sand		11	21	10
Silty Sand w/ gravel		21	34	13
Sandy Gravel		34	44	10
Gravelly Sand		44	59	15
Gravelly Silty Sand		59	68	9
Sand		68	88	20
Silty Sand trace Gravel		88	100	12
Lean Clay		100	113	13
38.568728° N				
118.622440° W				
NAD 27 (TA)				
~~Abandon w/ Cement Grout~~		~~113~~	~~[illegible]~~	~~93~~
ABANDON w/ Neat Cement		~~20~~	~~0~~	~~20~~
		113	0	113
GPS coords: N 38° 34' 07.12"				
W 118° 37' 24.24"				
datum: WGS 84				

Date started 12/9, 2008
Date completed 12/9, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 113 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	113 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 107' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear
Contractor
Address 12464 McCann Dr.
Contractor
Santa Fe Springs, CAL. 90670
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2/11/08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY J03-SB2 (O)-627