WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109773
Permit No.
Basin 110C

NOTICE OF INTENT NO. 60959 ~~60966~~

1. OWNER Hawthorne Army Depot (Kevin Shumaw)
MAILING ADDRESS 25 Maine BLDG 5
Hawthorne, NV 89415
ADDRESS AT WELL LOCATION Hwy 95
Hawthorne Army Depot

2. LOCATION ~~NE SE~~ NW ¼ Sec. 9 T. 8 N S R. 30 E. Mineral County
PERMIT NO. M/10-1475/9-000031 Issued by Water Resources
Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other Temp

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	13	13
Cemented silty sand		13	53	40
Silty Sand INT/clay lenses		53	128	75
Silty Clay		128	133	5
Silty Sand INT/clay lenses		133	140	7
SAND		140	148	8
38.569853°N				
118.638927°W				
NAD 27 (TR)				
Abandon w/ Cement Grout		148	20	128
Abandon w/ Neat Cement		~~148~~	0	~~148~~
GPS coords: N 38° 34' 11.17"				
Datum: W 118° 38' 23.81"				
WGS 84				

Date started 12/12, 2007
Date completed 12/13, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 148 Feet Depth Cased Ø Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	148 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 119' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Contractor
Address 12464 McCann Dr. Contractor
Santa Fe Springs Cal. 90670
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed By driller performing actual drilling on site or contractor
Date 2/11/08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627