

Log No. _____
 Permit No. _____
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57134

1. OWNER Hyons County Utilities ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 34 Lakes Blvd 14776338.5 N
Dayton NV, 89403 2255530.3 E NAD83
 2. LOCATION SE 1/4 Sec. 5 T. 16 N. R. 22 E. Hyons County _____
 PERMIT NO. R-018 Issued by Water Resources Parcel No. 016-351-15 Subdivision Name Well # 16-22-5-SW-2

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy S. H		0	7	
Brown Silty sand dry to moist		7	12	
Light brown sand		12	14	
DK brown sandy silt		14	15	
Gray sand		15	17	
Fine to coarse TAN sand med to coarse	L	17	40	

39.277210° N
 119.534987° W
 April 27 (TOD)

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40	6	35

Perforations:
 Type perforation slots
 Size perforation 0.20
 From 25 feet to 35 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 23 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 23 feet to 35 feet

9. WATER LEVEL
 Static water level 17.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WDC Contractor
 Address Po Box 191 Contractor
Zamora LA 95690
 Nevada contractor's license number issued by the State Contractor's Board 12852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111
 Signed Jim Whitley
 By driller performing actual drilling on site or contractor
 Date 1-8-08

Date started 9-7 2007
 Date completed 9-7 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>pump</u>	<u>1</u>	<u>1.2</u>	<u>1:00</u>