


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY **109798**

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin **1378**

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61059

1. OWNER New West Gold Inc.  
MAILING ADDRESS 230 South Rock Blvd. Suite 30  
Reno, NV 89502

ADDRESS AT WELL LOCATION North Umlerland  
Hole #NU#1

Subdivision Name: \_\_\_\_\_ County: Nye

2. LOCATION NE 1/4 NW 1/4 Sec 24 T 13N N/S R 45 E Latitude UTM E 512236  NAD 27  
PERMIT/WAIVER No. M/O-1526 Longitude N 4312430  NAD 83/WGS 84

Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	7	7
Limestone thin clay layers		7	680	673
Hole was drilled to 680' neat cement pumped from 680' to 560'. 2" casing was set from 560' to 0'				
<u>N38,960816</u>				
<u>W 116,857856 NAD27</u>				

9. WELL CONSTRUCTION

Depth Drilled 680 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>14</u> Inches	<u>0</u> Feet <u>20</u> Feet
<u>8.5</u> Inches	<u>20</u> Feet <u>680</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>		<u>Sch. 80 Perf.</u>	<u>410</u>	<u>560</u>
<u>2 3/8</u>		<u>Sch. 80 Blank</u>	<u>0</u>	<u>410</u>

Perforations:

Type of perforation \_\_\_\_\_ Machine \_\_\_\_\_  
Size of perforation \_\_\_\_\_ 0.01

From 410 feet to 560 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 560 to 680  Pumped  Poured  
 Cement Grout 0 to 400  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 560 to 407  Pumped  Poured  
Type: #8 Sand

Bentonite Chips:  Yes  No 407 to 400  Pumped  Poured  
Type: Coated 3/8" Bentonite Pellets

7. Water Level  
Static water level: Dry feet below land surface  
Artesian Flow: No G.P.M. N/A P.S.I.  
Water Temperature: None °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Baller  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
_____	_____	_____
_____	_____	_____
_____	_____	_____

STATE ENGINEERS OFFICE  
2008 DEC 8 AM 11:34

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drilling Company, Inc.  
Contractor

Address PO Box 2748  
Contractor

Elko, NV 89803

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1395

Signed George M. Adkins  
By driller performing actual drilling on site or contractor

Date 11/23/2008