WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 109880
Log No.
Permit No.
Basin Ø64

NOTICE OF INTENT NO. 57772

1. OWNER David Itza
MAILING ADDRESS P.O. Box 578 Battle Mtn 89820
ADDRESS AT WELL LOCATION 380 Dillon CT.

2. LOCATION SE SW ¼ Sec. 24 T. 32 N S R. 44 E. Lander County
PERMIT NO. Issued by Water Resources | Parcel No. 91-050-29 | Subdivision Name J.S.F

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Sand Gravel		10	20	10
Tan Clay		20	30	10
Blue Clay		30	70	40
Tan Clay		70	95	25
Sand		95	100	5
Tan Clay		100	115	15
Blue Clay		115	120	5

Latitude ____ UTM E 11502727 ☒ NAD 27
Longitude ____ N 4497069 ☐ NAD 83/WGS 84

RECEIVED 2006 AUG 14 AM 11:30 STATE ENGINEERS OFFICE

40.626350°N
116.967757°W
NAD 27 (T2)

Date started 7-21, 2006
Date completed 7-22, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	UNK	1

2007 MAR 14 AM 10:56

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 120 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type perforation Sawed
Size perforation 3/16 X 3
From 90 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
(60'-70' = Hole Plug)
Gravel Packed: ☒ Yes ☐ No
From 70 feet to 120 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name L.B.J. Drilling Co. Contractor
Address P.O Box 902 Contractor
Winca 89446
Nevada contractor's license number issued by the State Contractor's Board 9605
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed Joe Boggs By driller performing actual drilling on site or contractor
Date 8-9-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627