STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109892
Permit No.
Basin 090

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 65167

1. OWNER Washoe County School District
MAILING ADDRESS 7495 S. Virginia Street

ADDRESS AT WELL LOCATION Facility ID #D-000728
931 Southwood Blvd. Incline Village, NV
Subdivision Name: County: Washoe

2. LOCATION SW ¼ ~~SW ¼~~ Sec 15 T 16N N/S R 18 E
PERMIT/WAIVER No. 127-030-16 (Issued by Water Resources) Parcel No.
Latitude 39°14'49.65"N
Longitude 119°56'47.33"W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Loose Sand | | 0 | 12 | 12 |
| Clay with Sand | | 12 | 18 | 6 |
| Sandy Clay, Brown | | 18 | 22 | 4 |
| Clay with some Sand, Brown | | 22 | 29 | 7 |
| Sand Clay, Brown | | 29 | 35 | 6 |
| Clay, Dark Brown | | 35 | 40 | 5 |

39.247217°N
119.945459°W
NAD 27 (TM)

2010 JAN 11 PM 12:33

Date started: 3-Jan, 20 10
Date completed: 3-Jan, 20 10

7. Water Level
Static water level: 27 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6 | Inches | 0 | Feet | 40 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | SCH 40 | 0 | 8 |
| | | | | |
| | | | | |

Perforations:
Type of perforation Slot
Size of perforation .020
From 8 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 5 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 40 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 5 to 8 ☒ Pumped ☐ Poured
Type: Medium

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Cascade Drilling, L.P.
Address (Contractor) 3632 Omec Circle
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the State Contractor's Board C23-0073966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1977
Signed (by driller performing actual drilling on site or contractor)
Date 5-Jan-10

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY