STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109900
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62535

1. OWNER Mr. Aman Signh
MAILING ADDRESS 20255 Cold Springs Drive
Reno, NV

ADDRESS AT WELL LOCATION Facility ID 4-000744
20255 Cold Springs Drive Reno, NV
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 20 T 21N N/S R 18 E
PERMIT/WAIVER No. 087-283-01
Issued by Water Resources Parcel No.

Latitude 39°40'07.80" UTM E [X] NAD 27
Longitude 119°59'43.54" N [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blank		0	15	15
Screen		15	30	15

39.668833 -N
119.995428°W
NAD 27

Date started: 15-Apr, 20 09
Date completed: 15-Apr, 20 09

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	30

Perforations:
Type of perforation Slot
Size of perforation .020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 11 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 15 to 30 [ ] Pumped [X] Poured
Type: Sand #3
Bentonite Chips: [X] Yes [ ] No 11 to 15 [ ] Pumped [X] Poured
Type: 3/8 Chips

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova
Nevada contractor's license number issued by the *State Contractor's Board* C23-0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1977
Signed (By driller performing actual drilling on site or contractor)
Date 30-Dec-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY