

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. *37112*

Consultant: _____ Client: _____
 1. OWNER CDM Engineers & Construction ADDRESS AT WELL LOCATION Vista Canyon Group
 MAILING ADDRESS 50 West Liberty St. Suite 770 Sparks Solvent Fuel Site
Reno, N.V. 89502 Sparks, N.V.
 2. LOCATION SW 1/4 NE 1/4 Sec 9 T. 19 n. N/S R. 20 E Washoe County
 PERMIT NO. MW-221A 034-102-14 Sparks Solvent Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Moist, loose, gray brown, cmf sand, little silt		0	10	10
As Above, little gravel below 9 feet		10	17	7
Moist, medium dense, gray brown, cmf SAND and cmf GRAVEL		17	20	3
As Above, wet below 20 feet		20	25	5
As Above, color change to brown gray below 25 feet		25	35	10

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 27.3 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" 5/8 Inches To 0 Feet 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	W/CAP	SCH 40 PVC	0	7
12 in. Dia.	Steel	Manhole		
Threaded	PVC	Endcap		

 Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 0.06 in. Slot Screen
 From 7 feet to 27.3 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0-2.8 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal At: 2.8-5.0 ft.
 Gravel Packed: Yes No Coarse Aquarium
 From 5 feet to 35 feet

Date started 10-31-97, 19____
 Date completed 11-03-97, 19____

7. WELL TEST DATA

	TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

9. WATER LEVEL
 Static water level not known feet below land surface
 Artesian flow _____ G.P.M. n/a P.S.I.
 Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, N.V. 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date September 9, 2000