DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11112
Permit No. 24618
Basin Smith Val.
250B6-7

1. OWNER Robert H. Griffin ADDRESS Wellington Nev
Stanley Howewill Wellington Nev

3ABCC1

2. LOCATION N ¼ NE ¼ Sec. 3 T. 11 N N/S R. 23 E. Lyon County
PERMIT NO. 24618

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	6
Gray Clay		6	15	9
Coarse Sand		15	40	25
Coarse Gravel-Red Clay		40	52	12
Red Clay-Small Gravel		52	78	26
Brown Gritty Clay		78	95	17
Gray Gritty Clay		95	140	45
Gravely Gray Clay		140	158	18
Coarse Sand-Gravel	X	158	180	22
Dark Gray Silty Clay Some Gravel		180	235	55
Hard Rock-Boulders		235	254	19
Firm Gravel/w Some thin soft strata	X	254	290	36
Gravel & Clay	X	290	304	14
Hard Rock		304	306	2
Very Firm Gravel	X			
Some thin soft strata	X	306	385	79
Light Brown Rock & Gravel-Hard	X	385	397	12
Hard Rock		397	408	11
Softer-Some				
Brown Clay	X	408	414	6
Hard Purple				
Brown Rock		414	420	6

Date started May 28, 1970
Date completed June 6, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 420 feet
Casing record 420
Weight per foot ..... Thickness ¼"

Diameter	From	To
14 inches	0 feet	420 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 420 feet

Perforations:
Type perforation Saw Slot
Size perforation ⅛ x 3"
From 150 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Fred Ash & Sons
Name Edward J. Ash
Address 205 Castroville Blvd Salinas
Nevada contractor's license number 10097
Nevada driller's license number 577
Signed Edward J. Ash
Date June 11, 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471