

OFFICE USE ONLY
 Log No. 11128
 Permit No. 25515
 Basin steptoe Val 179

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Doug Spidler ADDRESS East Ely, Nevada

2. LOCATION NW 1/4 NE 1/4 SW 1/4 NE 1/4 Sec. 14 T. 16 N N/S R. 63 E White Pine County
 PERMIT NO. 25515

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>Clay</u>		<u>7</u>	<u>27</u>	<u>20</u>
<u>Clotted top material</u>		<u>27</u>	<u>85</u>	<u>58</u>
<u>Compressed gravel</u>		<u>85</u>	<u>135</u>	<u>50</u>
<u>Clotted hard gravel</u>		<u>135</u>	<u>160</u>	<u>25</u>
<u>Stringers</u>				

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 165 feet
 Casing record.....
 Weight per foot 8.7 Thickness 0.22

Diameter	From	To
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type.....
 Depth of seal..... feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation torch perforations
 Size perforation 1/8 x 6
 From 42 feet to 160 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL
 Static water level 18 Feet below land surface 18
 Flow..... G.P.M.
 Water temperature 53 ° F. Quality Good

Date started June 1, 1970
 Date completed June 18, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ronald Jordan
 Address P.O. Box 937, Ely, Nevada
 Nevada contractor's license number 9329A
 Nevada driller's license number 428
 Signed Ronald Jordan
 Date July 6, 1970

BAILER TEST

G.P.M. <u>150</u>	Draw down <u>1.0</u> feet	<u>1/2</u> hours
G.P.M. <u>160</u>	Draw down <u>1.5</u> feet	<u>1/2</u> hours
G.P.M. <u>185</u>	Draw down <u>1.5</u> feet	<u>1</u> hours