DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11361
Permit No.
Basin Pleasant V

1. OWNER W. C. BILL ROBERTS ADDRESS 355 ANDREW LN. RENO

2. LOCATION SW ¼ SE ¼ Sec. 4 T. 17 N/S R. 20 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Sandy Clay		1	15	14
Sandy Clay Rock	W	15	28	13
Clay Rock		28	35	7
Sandy Clay	W	35	75	40
White Clay Sand		75	80	5
Hard Sandy Clay		80	90	10
98% Temp at 90'				
Hole Back Filled To 79 FT				

Date started Jan 16, 1971
Date completed, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 45 Draw down 10 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 90' feet
Casing record
Weight per foot Thickness

Diameter	From	To
10 inches	0 feet	35 feet
6 inches	35 feet	80 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 Feet below land surface 10'
Flow G.P.M.
Water temperature 82 ° F. Quality TASTES Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Address Sparks
Nevada contractor's license number
Nevada driller's license number
Signed
Date

USE ADDITIONAL SHEETS IF NECESSARY

5471