DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11[illegible]
Permit No. 25972
Basin Golden Valley

1. OWNER North Park Company ADDRESS Arlington Towers Suite 270
100 North Arlington Ave Reno, Nevada 89501

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 20 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Red Sandy Clay		4	48	44
Granite (very Hard)		48	50	2
Sandy Clay w/ DC & Sc Boulders		50	80	30
Sandy Clay w/ DC & Sc Gravel Stgrs		80	117	37
Granite Boulders		117	125	8
Sandy Clay		125	130	5
Gravel & Clay		130	135	5
Blue-Green Sticky Clay		135	145	10
Granite w/ clay Stgrs		145	169	24
Granite Broken		169	173	4
Granite (Very Hard)		173	184	11
Granite Broken Formation lost Some Drilling Fluid	yes	184	192	8
Granite (Very Hard)		192	198	6
Granite Broken Formation, lost Some drilling fluid	yes	198	211	13
Granite (Very Hard)		211	216	5

Date started January 4, 19 71
Date completed January 18, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	10	84'	12 hours

BAILER TEST
G.P.M. 8 Draw down 80 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 16 5/8 inches Total depth 216 feet
Casing record 6 5/8, Surface to TD
Weight per foot Thickness 3/16

Diameter	From	To
6 3/8 inches	0 feet	216 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from TD feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 3
From 116 feet to 216 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 96 Feet below land surface
Flow None G.P.M. None
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hoover & Sons Const. Co.
Address 9310 Pan American
Nevada contractor's license number 3884-A
Nevada driller's license number 631
Signed [illegible]
Date Feb. 2, 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471