DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11508
Permit No. 25728
Basin Eagle Val

1. OWNER FRONTIER ENTERPRISES ADDRESS De Luxe Motel
CARSON City - Nev. - 1931 North CARSON St.

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 15 N N/S R. 20 E. ORMSBY County
PERMIT NO. 40786

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	12	12
Medium Sand -		12	18	6
Clay		18	20	2
Fine gravel		20	28	8
Med. gravel		28	34	6
Clay		34	44	10
D.G. Cemented -		44	60	16
Fine Sand.		60	67	7
D.G. Cemented.		67	78	11
Sand. Medium -		78	80	2
D.G.		80	88	8
Sand - Medium.		88	90	2
D.G -		90	94	4
Sand -		94	96	2
D.G -		96	112	16
Sand -		112	116	4
D.G.		116	144	28
Sand -		144	147	3
D.G.		147	154	7
Sand, Course		154	158	4
D.G.		158	175	17
Gravel - Medium		175	180	5
D.G.		180	220	40
Sand -		220	226	6
Clay & Gravel		226	267	41
Sand -		267	272	5
Boulders & Clay -		272	284	12

Date started Dec 11, 19 70
Date completed FEB. 13, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	350	80	31
Plugged by Well Log No. 117833			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 0-50-34" WELL CONSTRUCTION
Diameter hole 24 inches Total depth 284 feet
Casing record
Weight per foot Thickness .250

Diameter		From		To	
26"	inches	+1	feet	50 -	feet
12"	inches	+1	feet	284	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50 Ft. - feet
Gravel packed: Yes ☑ No ☐
Gravel packed from +2 feet to 284 feet

Perforations:
Type perforation Milled -
Size perforation 1/8 x 3 -
From 74 feet to 284 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 inches Feet below land surface
Flow G.P.M.
Water temperature 63 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ENLOE DRILLING Co
Address 1450 Valley View Drive CARSON City -
Nevada contractor's license number 4739
Nevada driller's license number 249
Signed Floyd Enloe
Date april 26 - 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471