DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11520
Permit No. 26099
Basin Smith Val

1. OWNER Peggy Wallace ADDRESS Box 31 A South Washington, Nevada
Mason Valley Country Club
2. LOCATION NW ¼ NE ¼ Sec. 27 T. 13 N N/S R. 25 E. MDB&M Lyon County
PERMIT NO. 26099

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	10	10
Sand		10	57	47
Sandy Gravel		57	124	67
Gravel		124	172	48
Clay		172	195	23
Gravel		195	260	65

Date started 4/8/, 1971
Date completed 4/20, 1971

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1600	750	62'	15

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 18 3/4 inches Total depth 260' feet
Casing record .....
Weight per foot ..... Thickness 1.88

Diameter	From	To
10 3/4 inches	0 feet	260' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 260 feet

Perforations:
Type perforation Slot - Mills
Size perforation 3/32 x 3
From 200 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 10 Feet below land surface .....
Flow — G.P.M. —
Water temperature 55 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name George E. Whatley
Address 513 W. Bridge St.
Nevada contractor's license number 7840
Nevada driller's license number 6440
Signed George E. Whatley
Date 4/25/71

USE ADDITIONAL SHEETS IF NECESSARY

5471