

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65564

1. OWNER Frank Peglar ADDRESS AT WELL LOCATION Silver City
 MAILING ADDRESS PO Box 494 Silver City, NV 89429 NO ADDRESS
 2. LOCATION SE 1/4 SE 1/4 Sec. 17 T. 16 N/S R. 21 E. 140N County
 PERMIT NO. 77581 Issued by Water Resources Parcel No. 09-061-06 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE Const.
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|--------------|------|-----|-----------|
| Dirt Rock & clay | | 0 | 22 | 22 |
| Green rock | | 22 | 54 | 32 |
| Associated colored frac. rock | | 54 | 75 | 21 |
| Small colored rock | | 75 | - | 55 |
| Sof green clay | X | - | 130 | 570+5 |
| Associated colored rock | X | 130 | 145 | 15 |
| Medium to large board rock with some clay | X | - | 257 | 112 |
| Hard rock and Fractures | | 257 | 275 | 18 |
| Associated colored sand & Fractures | X | 275 | 318 | 43 |
| Black Fractures | | 318 | 340 | 22 |
| Associated Fractures and | X | 340 | 377 | - |
| Small sand colors | X | - | 377 | 37 |

8. WELL CONSTRUCTION
 Depth Drilled 377 Feet Depth Cased 377 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 102 Feet
 9 7/8 Inches 102 Feet 377 Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 9/8 | | .188 | +2 | 377 |

Perforations:
 Type perforation Buzz Saw
 Size perforation 3/16 x 6 inch
 From 176 feet to 252 feet
 From 273 feet to 315 feet
 From 336 feet to 377 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 102
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 102 feet to 377 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow NO G.P.M. 80+ P.S.I.
 Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Well Drilling Contractor
 Address PO Box 1255 Contractor
CC NV 89422
 Nevada contractor's license number 46497 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2137
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 7.10.10

Date started 6-16, 2010
 Date completed 6-19, 2010

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>80+</u> | | <u>3 hrs</u> |

NAD-27 GPS
39.261717° N
119.641800° W