

OFFICE USE ONLY
 Log No. 11725
 Permit No. 26321
 Basin Claviers Area *CRD*

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER 25 Corporation ADDRESS Battle Mountain, Nevada

2. LOCATION center SW $\frac{1}{4}$ Sec. 24 T. 34 N. 44 E. Lander County
 PERMIT NO. 2

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy topsoil		0	4	4
Hard yellow clay		4	23	19
Yllw. clay w/ alternate coarse sand streaks x (first water @ 112')		23	167	144
Hard & soft blue clay w/ coarse sand lenses- inconstantly water bear.		167	281	114
Fine to coarse sand w/ rounded gravels to $\frac{1}{2}$ "	x	281	310	29
Hard & soft sandy yellow clay		310	345	35

8. WELL CONSTRUCTION

Diameter hole 14 inches Total depth 345 feet
 Casing record 12 5/8" OD x 345'
 Weight per foot _____ Thickness $\frac{1}{2}$ wall

Diameter	From	To
<u>12 5/8" OD</u> inches	<u>0</u> feet	<u>345</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 345 feet

Perforations:
 Type perforation Factory saw cut
 Size perforation 1/8" X 3"
 From 147 feet to 346 feet
 From _____ feet to _____ feet

Date started May 10, 1971, 19_____
 Date completed May 16, 1971, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1600</u>	<u>12000</u>	<u>62'</u>	<u>34</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 50 Feet below land surface
 Flow _____ G.P.M.
 Water temperature NORM. F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address 1955 18th Street; Sparks, Nev
 Nevada contractor's license number 9767
 Nevada driller's license number 493
 Signed W.L. McDonald
 Date 7-22-71