DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1187
Permit No.
Basin Washoe V

1. OWNER Ballard Homes ADDRESS 545 Northridge Dr. Reno, Nevada

2. LOCATION ¼ ¼ Sec. 31 T. 16 17 N/S R. 19 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
Yellow sandy clay		8	15	7
Brown Sandy clay with boulders		15	23	8
D. G. with brown clay		23	53	30
Fine sand	Yes	53	57	4
Brown sandy clay		57	69	12
Coares sand	Yes	69	81	12
Gray sandy clay		81	84	3

Date started Oct. 11, 19 71
Date completed Oct 12, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	10	17	5

BAILER TEST
G.P.M. None Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 84KB feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	81 KB feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type ~~CXXXX~~ Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 84 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 1/8 X 3
From 81 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 28 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hoover & Sons Const. Co.
Address 9310 Pan American Way
Nevada contractor's license number 3884-A
Nevada driller's license number 631
Signed [signature]
Date [illegible]

USE ADDITIONAL SHEETS IF NECESSARY

5471