STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11951
Permit No. 26699
Basin Dayton Val

1. OWNER Marvin Pickles - ADDRESS Box 66 - Dayton, Nev.
Lot 18 - Dayton Valley Ranches -

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 16 N/S R. 22 E. Lyon County
PERMIT NO.

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.C. Sand -		0	10	10
Boulders & Clay		10	60	50
Clay -		60	68	8
Cobbles -		68	75	7
Clay & Cobbles -		75	91	16
Clay -		91	102	11
Sand -	+	102	103	1
Brown Clay -		103	130	27
Sand & gravel	+	130	145	15

Date started Sept 21, 19 71
Date completed Sept 30, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	30	20	4

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 16 inches Total depth 145 feet
Casing record
Weight per foot 17 Thickness 188

Diameter	From	To
8 5/8 inches	+1 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal - 3 - 50 ft - feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 145 feet

Perforations:
Type perforation Milled -
Size perforation 1/8 x 2½
From 100 feet to 145 - feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 64 Feet below land surface
Flow G.P.M.
Water temperature 64 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co -
Address 1450 Valley View Drive Carson City - Nev
Nevada contractor's license number 4739
Nevada driller's license number 249 -
Signed [signature]
Date Nov 10 - 71

USE ADDITIONAL SHEETS IF NECESSARY