

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 59939

1. OWNER Mike Morris ADDRESS AT WELL LOCATION Lot 12 Block 22
 MAILING ADDRESS 1270 N. Hollywood Las Vegas NV 89110

2. LOCATION S25W 1/4 S20E 1/4 Sec. 12 T. 12 N. S. R. 61 E. White Pine County
 PERMIT NO. NA Issued by Water Resources Parcel No. 013-022-12 Subdivision Name Preston town site

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
Clay gravel cobbles		3	12	
Clay gravel		12	16	
gravel clay		16	25	
Clay gravel		25	30	
Clay		30	35	
Clay gravel		35	38	
Clay		38	58	
gravel	water	58	67	water
Clay	water	67	72	
gravel	water	72	80	water
Clay		80	87	
gravel	water	87	89	water
Clay		89	94	
gravel	water	94	98	
Clay		98	103	
gravel	water	103	107	
gravel	water	107	111	
Clay		111	125	
gravel	water	125	150	

38.911139°N
 115.061889°W N40 27 (T)

NAD 27 N 38° 54' 40.1"
 W 115° 03' 42.8"

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		3/40 PVC	10	150
6	12.9	188	-1	10'

Perforations:
 Type perforation Factory
 Size perforation .032 x 6 row

From _____ feet to _____ feet
 From 110 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 150 feet

Date started 12-10, 2009
 Date completed Jan 7, 2010

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	11.6	01:02 / hr

9. WATER LEVEL
 Static water level 65.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 64 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor
 Address P.O. Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Owner Maynard
 By driller performing actual drilling on site or contractor
 Date Jan 20 - 2010