

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110023
Permit No. _____
Basin 654

Facility ID # 6-006318

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33838

1. OWNER Bharta Spatpinder + Tosbink ADDRESS AT WELL LOCATION 3093 Crescent Ave
MAILING ADDRESS P.O. Box 21111 Crescent Valley, NV 89821 29N Subdivision Name: _____ County: Eureka

2. LOCATION SE 1/4 Sec X5 T 36 N R 48 E Latitude 40° 25.05 90 UTM E NAD 27
PERMIT/WAIVER No. NE 002-019-27 Longitude 116° 34.58 79 N NAD 83/WGS-84
Issued by Water Resources Parcel No. 40.417733°N 116.595546°W NAD 27 (TV)

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & clay		0	12	12'
Gravel sandy clay		12	60	48'
Gravel sand		60	72	12'
Sandy clay		72	85	13'
Sandy gravel		85	91	6'
Sandy clay gravel	X	91	109	18'
Hard Fine Sand		109	118	9'

9. WELL CONSTRUCTION

Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
8"	0	118	118

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	40 Sch	0	118

Perforations:
Type of perforation Pvc Screen
Size of perforation 0020

From 112 feet to 118 feet
From 82 feet to 107 feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 0 to 2' Pumped Poured
 30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 112 to 118 Pumped Poured
Type: Cemex 79 707 sand #3

Bentonite Chips: Yes No 2' to 79' Pumped Poured
Type: Kwik Plug Chips 3/8

7. Water Level
Static water level: 92 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name F. A. BLE Drilling Services LLC Contractor
Address 7150 Plack Street Contractor
Las Vegas NV 89119

Nevada contractor's license number 51266
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 8097

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 1-24-10

(Rev. 06-06) JAN 27 2010
LAS VEGAS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY