W 1

Facility ID # 6-000318

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110026
Permit No.
Basin Ø54

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33838

1. OWNER Bharta Spatpinder + Tasbirk
MAILING ADDRESS PO Box 211111 Crescent Valley NW NV 89821 29N
ADDRESS AT WELL LOCATION 3093 Crescent Ave Crescent Valley NV
Subdivision Name:
County: Eureka

2. LOCATION SE¼ SE¼ Sec 15 T 30 N S R 48 E
PERMIT/WAIVER No. NE 002-019-27
Issued by Water Resources
Parcel No.
Latitude 40°25.06.68
Longitude 116°34.58.11
UTM E N
☐ NAD 27
☒ NAD 83/WGS 84
40.417863°N 116.575433°W NAD 27 (TL)

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel & clay		0	12	12
gravel sandy clay		12	60	48
gravel sandy "		60	72	12
sandy clay		72	85	13
sandy gravel		85	91	6
sandy clay gravel	X	91	109	18
Hard Fine Sand		109	118	9

Date started: 12 15, 20 09
Date completed: 12 18, 20 09

9. WELL CONSTRUCTION
Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0	Feet	118	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	40 Sch	0	118

Perforations:
Type of perforation PVC Screen
Size of perforation 0.020
From 112 feet to 118 feet
From 82 feet to 107 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 2' ☐ Pumped ☒ Poured
☐ =30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 112 to 118 ☐ Pumped ☒ Poured
Type: Cemex 79 107 sand #3
Bentonite Chips: ☒ Yes ☐ No 2' to 79' ☐ Pumped ☒ Poured
Type: KWIK Plug chips 3/8

7. Water Level
Static water level: 92 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FABLE Drilling Services LLC
Contractor
Address 7150 Placid Street
Contractor
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2097
Signed [signature]
By driller performing actual drilling on site or contractor
Date 1-24-10

DCNR/DWR RECEIVED
JAN 27 2010
LAS VEGAS OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY