STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110140
Permit No.
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Notice of Intent No. 62528

1. OWNER Param Investment LLC
MAILING ADDRESS 18553 Spicer Lake Court Reno, NV
ADDRESS AT WELL LOCATION Facility ID - 4-000502 GMVE-1
4600 N Virgina Street Reno, NV
Subdivision Name Lot Block County Washoe

2. LOCATION NW SW Sec. 26 T. 20N N/S R. 19 E/W B.M.
PERMIT/WAIVER No. 003-091-18
Latitude 39.570255°N Longitude 119.823904°W N+D 27
UTM N 4383864 E 0257341 ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark Brown Sandy Gravel		0	4	4
Light Brown/White Sandy Clay		4	35	31
Light Brown/Grey Silty Clay		35	63	28
White/Light Brown Clay w/Sand		63	95	32

Date started: 15-Oct, 20 09
Date completed: 19-Oct, 20 09

9. WELL CONSTRUCTION
Depth Drilled 95 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
4	Inches	0	Feet	85	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	35

PERFORATION
Type of perforation Slot
Size of perforation .020
From 35 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

ANNULAR SEAL ☒ Yes ☐ No
☒ Neat Cement 0 to 30 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 33 to 85 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 30 to 33 ☐ Pumped ☒ Poured
Type: Medium

7. Water Level
Static water level: 57.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the State Contractors Board 0073966
Nevada driller's license number issued by the Division of Water Resources, the Engineer 1977 M-1977
Signed (By driller performing actual drilling on site or contractor)
Date 12-Feb-10

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY