

Hydro Resources Nevada, Inc.

4975 W. Winnemucca Blvd.

Winnemucca, NV 89445

Phone: 775-623-5259 Fax: 775-623-0307

NV Contractor's License
#56797

CA Contractor's License
#832718

Log# 110/153
pg 2 of 2

February 19, 2010

Mark Sivazlian, Staff Engineer
NV Division of Water Resources
901 S Stewart St, Suite 2002
Carson City, NV 89701-5250

RE: Letter on Rejection of Proof of Completion of Work (POC) for Permit 68302
Robert R. Dexter and Wendy J. Dexter

Dear Mr. Sivazlian:

I am writing in response to the letter copy, dated 12/30/2009, we received regarding the rejection of completion of work for the Robert Dexter well.

We have gone out recently and placed a 100 foot seal in the well. We pulled the pump out of the hole, then using a drill rig, reversed out all the gravel down to 100 feet. We then pumped bentonite grout through a trimmie pipe from 100 feet to ground surface. Ray Wilson, Nevada license number 1713, was our driller who performed the work.

I am attaching a revised well log for this procedure. Should you have any additional questions, please contact us. Thank you.

Sincerely,

Steve Sweat/cj

Steve Sweat
Drilling Supervisor

STATE OF NEVADA
2010 FEB 24 AM 11:02