

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY 110/68
 Log No.
 Permit No.
 Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65311

1. OWNER **Robinson NV Mining** **RP10-02** ADDRESS AT WELL LOCATION **Ruth, NV.**
 MAILING ADDRESS **PO Box 382**
NW **Ruth, NV. 89319** Subdivision Name: _____ County: **White Pine**
 2. LOCATION **NE 1/4 SE 1/4 Sec 15 T16N R62E** Latitude 39.249445° N UTM E **674698** NAD 27
 PERMIT/WAIVER NO. **m/o - 1482** Longitude 114.975519° W **4346203** NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORK PERFORMED New Well Replace Recondition
 Deepen Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	20	20
Brown Limestone		20	440	420
Grayish Brown Limestone		440	525	85
Gray Limestone		525	650	125
Greenish Gray Skarn		650	735	85
Marble Mineralized Brown to Gray Limestone		735	930	195
Dark Brown Limestone		930	1080	150
Gray Limestone		1080	1155	75
Black Limestone		1155	1175	20
Gray Limestone		1175	1190	15
Black Limestone		1190	1265	75
Gray Limestone		1265	1300	35

9. WELL CONSTRUCTION
 Depth Drilled **1300** Feet Depth Cased **0** Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12.075 Inches **0** Feet **25** Feet
6.50 Inches **25** Feet **885** Feet
6.125 Inches **885** Feet **1300** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.625	23.54	.301	0	25 (TA)

Perforations:
 Type of perforation _____
 Size of perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 25 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 =30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No _____ to _____ Pumped Poured
 Type: _____
 Bentonite Chips: Yes No 25 to 1300 Pumped Poured
 Type: **Abantonite**

Date started: **February 20**, 20 **10**
 Date completed: **February 26**, 20 **10**
 7. Water Level
 Static water level: **700** feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: **65** °F
 Quality: **good**

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	Draw Down		Time (Hours)
G.P.M.	(Feet Below Static)		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Boart Longyear** (CONTRACTOR)
 Address **2745 California Ave.** (CONTRACTOR)
SLC., UT. 84104
 Nevada contractor's license number issued by the State Contractor's Board **0021976**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2308**
 Signed _____
 By driller performing actual drilling on site or contractor
 Date **March 3, 2010**

See Plugging log #
Hole was Abandoned per Regulations 110/69