STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110171
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65310

1. OWNER Robinson NV Mining RP10-01
MAILING ADDRESS PO Box 382
Ruth, NV. 89319

ADDRESS AT WELL LOCATION Ruth NV.
Subdivision Name: County: White Pine

2. LOCATION NE¼SE¼ Sec15T16N/ R62E
PERMIT/WAIVER NO. m/o-1482 (Issued by Water Resources) Parcel. No.

Latitude 39.249136°N UTM E 674978 ☒ NAD 27
Longitude 114.972203°W N 4346175 ☐ NAD 83/WGS 84
NAD 27 (FB)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	20	20
Brown Limestone		20	105	85
Dark Gray Limestone		105	145	40
Light Gray Limestone		145	225	80
No sample		225	240	15
Brown Limestone		240	330	90
Dark Gray Limestone		330	340	10
Brown Limestone		340	410	70
Gray Limestone		410	585	175
Grayish White Limestone		585	650	65
Iron Stained Limestone		650	655	5
Grayish White Limestone		655	680	25
Dark Gray Limestone		680	845	165
Grayish White Limestone		845	905	60
Orange Clay		905	910	5
Grayish White Limestone		910	960	50
Dark Gray Limestone		960	1065	105
Grayish White Limestone		1065	1110	45
Gray Limestone/Orange Clay		1110	1120	10
Gray Limestone		1120	1145	25
Gray limestone/Orange Clay		1145	1155	10
Gray Limestone		1155	1170	15
Brown Clay		1170	1175	5
Gray Limestone		1175	1255	80
Gray/Brown Clay		1255	1280	25
Gray Limestone		1280	1305	25
Hole was Abandoned				
per Regulations				

Date started: February 16, 20 10
Date completed: February 20, 20 10

7. Water Level
Static water level: 650 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: 65 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 1305 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.75 Inches	0 Feet	25 Feet
6.50 Inches	25 Feet	645 Feet
6.25 Inches	645 Feet	1305 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 10 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ =30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 10 to 1305 ☒ Pumped ☐ Poured
Type: Abantonite

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2308
Signed
By driller performing actual drilling on site or contractor
Date March 3, 2010

2010 MAR -8 AM 11:50

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

*See Plugging Log # 110170