

CUST 1  
STW 1

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY 110190

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 064

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

59632

NOTICE OF INTENT NO.

1. OWNER David ITZA  
MAILING ADDRESS P.O. Box 578  
Battle Mtn NV 89820  
2. LOCATION N 1/4 SW 1/4 Sec 24 T 32 N R 44 E  
PERMIT/WAIVER No. 11-040-02  
Issued by Water Resources Parcel No. \_\_\_\_\_

ADDRESS AT WELL LOCATION 455 BUENA VISTA  
BATTLE MTN HANDEN  
Subdivision Name: \_\_\_\_\_ County: \_\_\_\_\_  
Latitude 40.631693°N UTM E 502394  NAD 27  
Longitude 116.971692°W N 4497662  NAD 83/WGS 84  
NAD 27 (U)

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Rotary  RVC  
 Cable  Air  Other

6. LITHOLOGIC LOG

| Material          | Water Strata | From | To  | Thick-ness |
|-------------------|--------------|------|-----|------------|
| Top Soil          |              | 0    | 5   | 5          |
| Hard Clay         |              | 5    | 20  | 15         |
| Brown Sandy Clay  |              | 20   | 40  | 20         |
| Brown + Blue Clay |              | 40   | 60  | 20         |
| Blue Clay         |              | 60   | 100 | 40         |
| SAND + GRAVEL     |              | 100  | 117 | 17         |

9. WELL CONSTRUCTION  
Depth Drilled 117 ft Feet Depth Cased 117 Feet  
HOLE DIAMETER (BIT SIZE)  
Inches From 0 To 117 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 7/8</u>       |                     | <u>0.113</u>            | <u>71</u>   | <u>117</u> |

Perforations:  
Type of perforation SAWED  
Size of perforation 3/16 x 3  
From 97 feet to 117 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 5 to 60  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 80% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 90 to 117  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No 60 to 90  Pumped  Poured  
Type: \_\_\_\_\_

Date started: NOV 8 20 07  
Date completed: NOV 10 20 07

7. Water Level  
Static water level: 12 ft feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cold °F  
Quality: Good

8. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|---|-----------|-------------------------------|--------------|
| <u>Rotary</u>   | <u>75</u> | <u>DNE</u>                    | <u>2 Hrs</u> |

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LBJ DRILLING & PUMP COMPANY, INC. Contractor  
Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0009605A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807  
Signed Joe Boggio  
By driller performing actual drilling on site of contractor Joe Boggio  
Date 11-28-07