

cust 1
Stable 1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110193
Permit No.
Basin \$69

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 0
3820 FlintHocks Dr.
Humboldt

1. OWNER DANIEL McVey
MAILING ADDRESS 3820 FlintHocks Dr.
WMOA NV 89445
2. LOCATION SW 1/4 NE 1/4 Sec 19 T 39 N/S R 39 E
PERMIT/WAIVER No. 1006-272-10
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION
Subdivision Name: County:
Latitude UTM E NAD 27
Longitude N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Rotary RVC
 Cable Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	10	10
HARD SANDY CLAY		10	20	10
SOFT CLAY		20	100	80
SAND + SMALL GRAVEL		100	120	20
HARD CLAY		120	140	20
SAND + SMALL GRAVEL		140	160	20

9. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Inches	From	To	Feet
10 5/8	0	160	160				

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		0.188	71	160

Perforations:

Type of perforation Torch Cut
Size of perforation 2 1/2 x 3

From	feet to	feet
120	160	160

Annular Seal: Yes No

Material	to	Feet	Method
<input type="checkbox"/> Neat Cement			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	5	55	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> 80% Bentonite Grout			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	90	160	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
Type:			
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	55	90	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
Type:	3/8		

7. Water Level
Static water level: 71 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60/9 °F
Quality:

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
ROTARY	75	UNK	3 Hrs

ED: 11/16/12

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor

Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0009605A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807

Signed Joe Boggio
By driller performing actual drilling on site

Date