WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110206
Permit No.
Basin 162

NOTICE OF INTENT NO. 33207

1. OWNER MIKE BROWN
MAILING ADDRESS 1891 E MANSE RD
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 1891 E MANSE RD

2. LOCATION NE 1/4 NE 1/4 Sec. 11 T 21S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 44-301-22 (Parcel No.) JOCELYN ESTATES (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [X] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" STEEL WELL. CLEAR WELL OUT TO 125'. SILT IN WELL FROM 95' TO 125'. HIT STEEL IN WELL @ 125'. BLEW OUT SOME SUBMERSIBLE PUMP CABLE.				
N36°14'54.7" W115°97'66.7"				

MAR 0 2 2010

Date started 2/25/2010 , 19__
Date completed 2/25/2010 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled EXISTING Feet Depth Cased 8 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	EXISTIN	EXISTIN

Perforations:
Type perforation UNKNOWN
Size perforation UNKNOWN
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal EXISTING
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's licensenumber issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 2/26/2010

USE ADDITIONAL SHEETS IF NECESSARY