

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110312
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35188

1. OWNER TUPR LLC ADDRESS AT WELL LOCATION 200 S. Main St
MAILING ADDRESS 1 Main St MW-11 Las Vegas, NV
Las Vegas, NV 89101 Subdivision Name: _____ County: Clark

2. LOCATION NW 1/4 NW 1/4 Sec 34 T 20S N/S R 61 E Latitude 36.101537 UTM E NAD 27
PERMIT/WAIVER No. 13934101008 Longitude 115.085161 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	3	3
Sandy Clay		3	4	1
Silty Clay		4	5	1
Clayey Sand		5	11	6
Sandy Clay		11	14	3
Caliche		14	15	1
Silty Clay		15	17	2
Caliche		17	19	2
Silty Clay		19	25	6
Sandy Clay		25	27	2
Silty Clay		27	32	5

9. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 30 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 32
Inches Feet Feet Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 40	0	30

Perforations:
Type of perforation Factory Slotted
Size of perforation .010
From 10 feet to 30 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured
Gravel Pack: Yes No 8 to 32 Pumped Poured
Type: #3 Monterey Sand
Bentonite Chips: Yes No 1 to 8 Pumped Poured
Type: 3/4 Bentonite Chips

Date started: 11-Feb , 20 10
Date completed: 11-Feb , 20 10

7. Water Level
Static water level: 14.54 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
N. Las Vegas, NV, 89030
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381
Signed _____
By driller performing actual drilling on site or contractor
Date 3-3-10