

FINALIZED mm
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67632

1. OWNER Sue Abbott ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3050 Potbelly Rd. Winnemucca, NV. 89445 3050 Potbelly Rd. Winnemucca, NV. 89445
2. LOCATION SW 1/4 NE 1/4 Sec. 25 T. 35 S. R. 37 E Humboldt County _____
PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 14-143-22 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>cemented gravel and rock</u>	<u>Yes</u>	<u>155</u>	<u>250</u>	<u>95</u>
<u>N 40° 52.971</u>				
<u>W 117° 45.706</u>				
<u>NAD 27</u>				
<u>Deepens well log # 65756</u>				
<u>40.882, 850° N NAD 27 D.O.</u>				
<u>117.761, 767° W</u>				

8. WELL CONSTRUCTION
Depth Drilled 155 to 250 Depth Cased 47 to 250 Feet
HOLE DIAMETER (BIT SIZE)
From 6 Inches 155 Feet 250 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 3/8 (4.5")</u>	<u>N/C</u>	<u>Sched 40</u>	<u>140</u>	<u>250</u>

Perforations:
Type perforation Hand cut slot
Size perforation .125
From 230 feet to 250 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 5' N/A (see original log) Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 147 feet to 250 feet

9. WATER LEVEL
Static water level 110' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

Date started 4-17 2009
Date completed 4-27 2009

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Hand Pump</u>	<u>20</u>	<u>N/A</u>	<u>6</u>
<u>Pump</u>	<u>10</u>	<u>N/A</u>	<u>6</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. Contractor
Address P.O. Box 6 Lovelock NV. 89419 Contractor
Nevada contractor's license number 0071020 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Mark Mouty
By driller performing actual drilling on site or contractor
Date 4-20-09