FINALIZED MK

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110402
Permit No.
Basin 071

NOTICE OF INTENT NO. 63794

1. OWNER Rod & JoEtta Davis
MAILING ADDRESS 7305 Sunset Winnemucca, NV

ADDRESS AT WELL LOCATION 7305 Sunset Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION ~~SW~~ SE ¼NW¼ Sec13T35N / R37E
PERMIT/WAIVER NO. 13-533-05
Issued by Water Resources Parcel. No.

Latitude N40°91087 UTM E ☒ NAD 27
Longitude W117°76764 N ☐ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		115	120	5
gravel		120	125	5
clay		125	130	5
course gravel	X	130	170	40
clay		170	180	10
coble/gravel	X	180	210	30
rock		210	215	5

Deepening well log #31951

40.910,870°N NAD27 D.D.
117.767,640°W

Date started: March 18, 20 09
Date completed: March 19, 20 09

7. Water Level
Static water level: 91 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3

RECEIVED
2009 APR -2 AM 10:09
STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	115 Feet	215 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9	.188	115	215

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32X4
From 175 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Existing to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc. 4-6-09

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk - (213) 340-9429 - FormsOnADisk.com