

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110472
Permit No. _____
Basin 087

(same NOI as corresponding plugging log #11139)

NOTICE OF INTENT NO. 64101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Chris Dianda
MAILING ADDRESS 1050 South 21st Street
Sparks, NV 89431

ADDRESS AT WELL LOCATION 8525 Bellhaven Rd.
Reno, NV 89511
Subdivision Name: _____ County: Washoe

2. LOCATION NE ¼ NW ¼ Sec 11 T 18N R 19 E
PERMIT/WAIVER No. DOM08-015 041-130-02
Parcel No. _____

Latitude 39.44511 UTM E NAD 27
Longitude 119.81878 N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other x mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & rock		5	8	3
sand		8	18	10
clay & rock		18	37	19
clay		37	115	78
dg	x	115	143	28
clay		143	267	124
sand & stone	x	267	346	79
clay		346	410	64
sand & stone	x	410	423	13
clay		423	512	89
sand & stone	x	512	658	146
clay		658	680	22

Replaces well log #9358

*39.445, 199°N NAD27 D.D.
119.817, 757°W*

9. WELL CONSTRUCTION

Depth Drilled	680	Feet	Depth Cased	680	Feet
---------------	-----	------	-------------	-----	------

HOLE DIAMETER (BIT SIZE)

From		To	
10 5/8	Inches	0	Feet
8 3/4	Inches	110	Feet
	Inches		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	+2	680

Perforations:

Type of perforation	Size of perforation	From	feet to	feet
factory mill slot	3/32"	120	feet to	140
		260	feet to	300
		320	feet to	440
		520	feet to	540
		560	feet to	660

Annular Seal: Yes No

Neat Cement to _____ to _____ Pumped Poured

Cement Grout 0 to 100 Pumped Poured

Concrete Grout to _____ Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 100 to 680 Pumped Poured

Type: _____

Bentonite Chips: Yes No to _____ Pumped Poured

Type: _____

Date started: 19-Feb, 20 09
Date completed: 17-Mar, 20 09

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: cool °F
Quality: clear

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	15	100	85
	30	200	185
	50+	300	665

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc
Contractor

Address 4850 Joule St. Suite A5
Contractor

Reno, NV 89502

Nevada contractor's license number issued by the State Contractor's Board 14170

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121

Signed Steve McKay
By driller performing actual drilling on site Contractor

Date 3/18/2009