

Well plugged → NOI # 64164

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110426
Permit No.
Basin 105

FINALIZED
MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64152

1. OWNER Douglas County Sewer Improvement District
MAILING ADDRESS P.O. Box 578
Zephyr Cove, Nevada 89448

ADDRESS AT WELL LOCATION Muller Lane R-W; Approx 1/2 mile
west of US Highway 395
Subdivision Name: County: Douglas

2. LOCATION SW 1/4 SW 1/4 Sec 19 T 13N N/S R 20 E
PERMIT/WAIVER No. DEW-83
Issued by Water Resources Parcel No.

Latitude 38° 9' 70" UTM E NAD 27
Longitude 119° 7' 88" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other Dewatering

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	6	6
Brown Sandy Clay		6	10	4
Sand And Gravel		10	16	6
Blue Clay		16	20	4
GRS NAD-27				
39.970093° N				
119.786489° W				
See Plugging Log #110427				

9. WELL CONSTRUCTION

Depth Drilled	20	Feet	Depth Cased	20	Feet
HOLE DIAMETER (BIT SIZE)					
	From		To		
24	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	+1	20

Perforations:

Type of perforation	Mill Slot
Size of perforation	3" X .090
From 5	feet to 20
From	feet to

Annular Seal: Yes No
 Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 0 to 20 Pumped Poured
Type: 1/4" Pea Gravel
Bentonite Chips: Yes No to Pumped Poured
Type:

7. Water Level
Static water level: 5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stonehouse Construction & Excavation
Contractor
Address 3885 Wedekind Road
Contractor
Sparks, Nevada 89431
Nevada contractor's license number 0069994
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
Signed [Signature]
Date 4/1/2010

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)