FINALIZED MA

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110461
Permit No.
Basin 070

NOTICE OF INTENT NO. 62964

1. OWNER Betty Lashua
MAILING ADDRESS 7675 Moose Dr. Winnemucca NV 89445
ADDRESS AT WELL LOCATION 7675 Moose Dr. Winnemucca NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SE ¼ SW ¼ Sec 29 T 35 N/S R 37 E
PERMIT/WAIVER No. Issued by Water Resources
Parcel No.
Latitude 428792 Longitude 4525143
UTM E 428792 N 4525143 ☒ NAD 27 ☐ NAD 83/WGS 84
40.876171°N 117.845025°W NAD 27 (4)

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Rocky Clay		10	20	10
Rocky Clay		20	40	20
Rocky Clay + Some Sand		40	60	20
Rocky Clay		60	80	20
Rocky Clay + Gravel		80	100	—
Rocky Clay		100	120	20

Date started: 2-21, 2010
Date completed: 2-22, 2010

RECEIVED 2010 APR 15 AM 11:46 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation SAWed
Size of perforation 3/16 x 3
From 30 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 5 to 55 ☐ Pumped ☒ Poured
☒ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 70 to 120 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 55 to 70 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 35 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	60+	UNK	3 Hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed (By driller performing actual drilling on site or contractor) Joe Boggio
Date

(Rev. 06-06) USE ADDITIONAL SHEETS IF NECESSARY

PLO-I